

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2076

Dated:

It is certified that an inspection team headed by DR Sudhameha Shukla
(Name of Officers with designation) from Sri Samyog Saxena H.S.
(Name of Department/ Office) inspected the E.M.O. office
(Name & Address of the school) on 22.3.23 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year

Signature with Seal: [Signature]
Name : D.R. Asha Pandey
Designation : E.M.O. Prayagraj

[Signature] Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

MPVM Ganga Gurukulam
Gaddopur Phaphamau
Prayagraj
(Name & Address of the Institution)

मुख्य निमित्त अधि.
* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Kishna Jais

[Signature]
Principal
MPVM Ganga Gurukulam
Gaddopur, Phaphamau
Prayagraj-211013
CBSE Aff. No. 2130645
School Code-70020


ALLAHABAD JAL KAL VIBHAG LABORATORY

Result of the Bacteriological examination of the Water taken from Water Sample
 Name & Designation of the person collecting the sample Mr. Rajendra Prasad, Chemist

Date & time of collection	Date of receipt and inoculation	Source of Sample	Colony Count on agar plate in 1 ml.		Presumptive coliform count			Probable No. of coliform organism in 100 ml. of original water	Free residual chlorine mg/l	Remarks			
			At 37°C in 48 hours	At room temperature in 72 hours	Quantity of water put up in each tube/No. of tubes put up	50 ml.	10 ml.				1 ml.		
17/2/2023	17/2/2023	Water Sample Maharishi Pantangali Vidya Mandir: Campus Ganga Gurukulam Gaddopur, Phaphnau Prayagraj.			1	5	5	0	0	0	0	NIL	Excellent


Chemist

Chief Chemist



Ex. Engineer (HQ)
अधिराशी अभियन्ता (HQ)
जलकल विभाग, नगर निगम

19. Free Residual Chlorine
NS=Not Specified

0.2

NS

NIL


M. V. M. Ganga Gurukulam
Gaddopur, Phaphnau
Prayagraj-211013
Phone No. 2130645



PRAYAGRAJ JAL KAL VIBHAG LABORATORY.
CHEMICAL ANALYSIS OF WATER

Test Report

जलकल विभाग नगर निगम
प्रयागराज
पत्र संख्या 2076 म.प्र.ज.क.वि. 2023
दिनांक 22.2.2023


Sl. NO


1. Source of sample water Sample, Maharshi Panthayali Vidyā Mandir - Conjsus
2. Date of Sampling 17/2/2023 Received, Ganga Gurukulam, Gaddopur Phaphamau
3. Date of Analysis 17/2/2023 Prayagraj

Physico Chemical Parameter	BIS Limits IS 10500 : 2012		Result of test
	Requirement (Desirable Limit) Mg/l	Permissible limit In the absence of Alternate source Mg/l	
4. Total Dissolved solids	500	2000	427
5. Hardness Total as CaCO ₃	200	600	210
6. Hardness Temporary as CaCO ₃	NS	NS	105
7. Hardness Permanent as CaCO ₃	NS	NS	105
8. Chlorine as Chlorides Cl	250	1000	90
9. Total Alkalinity as CaCO ₃	200	600	45
10. Nitrites as NO ₂	NS	NS	Nil
11. Iron as Fe	0.3	No relaxation	0.1
12. Fluoride as F	1.0	1.5	0.6
13. Colour Hazen Unit	5	15	colourless
14. Taste	Agreeable	Agreeable	Not tasted
15. Odour	Agreeable	Agreeable	odourless
16. pH Value	6.5 to 8.5	No relaxation	6.8
17. Conductivity as μ mosh at 20°C	NS	NS	610
18. Turbidity NTU	1	5	1
19. Free Residual Chlorine	0.2	NS	Nil

Potable

Remarks


Chemist


Ex. Engg. (HQ)

अधिसायी अभियन्ता (मुख्यालय)
जलकल विभाग, नगर निगम

Copy forwarded for information to

- 1 The addl. Director, State Health Institute, Sector-C, Chetan Bihar, Aliganj, Lucknow, U.P.
- 2 Chief Medical Officer, Prayagraj.
- 3 Mukhya Nagar Swasthya Adhikari, Nagar Nigam. Prayagraj.
- 4 Nagar Ayukta, Nigar Nigam, Prayagraj.
- 5 The Suprintending Engineer (R&D) office of Addl. Chief Engineer (PPR&D), U.P. Jal Nigam, 6 Rana Pratap marg, Lucknow.
- 6 Chairman, jalkal Vibhag/Mayor, Nigam, Prayagraj.

Principal
MPVM Ganga Gurukulam
Gaddopur, Phaphamau
Prayagraj-211013
GBSE Aff. No. 2130645
School Code-70020

EX. Engg. (HQ)

